

Product Information

Brand Panasonic
Type of product Air-conditioner
Model name CS-TZ25TKEW + CS-TZ25TKEW / CU-2TZ50TBE

Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling	YES			Average (mandatory)	YES		
Heating	YES			Warmer (if designated)	NO		
				Colder (if designated)	NO		
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	5.00	kW	cooling	SEER	7.00	-
heating/Average	Pdesignh	4.50	kW	heating/Average	SCOP/A	4.20	-
heating/Warmer	Pdesignh	-	kW	heating/Warmer	SCOP/W	-	-
heating/Colder	Pdesignh	-	kW	heating/Colder	SCOP/C	-	-
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = 35°C	Pdc	5.00	kW	Tj = 35°C	EERd	3.85	-
Tj = 30°C	Pdc	3.50	kW	Tj = 30°C	EERd	5.40	-
Tj = 25°C	Pdc	2.25	kW	Tj = 25°C	EERd	9.17	-
Tj = 20°C	Pdc	1.47	kW	Tj = 20°C	EERd	14.36	-
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	3.74	kW	Tj = -7°C	COPd	2.60	-
Tj = 2°C	Pdh	2.28	kW	Tj = 2°C	COPd	4.11	-
Tj = 7°C	Pdh	1.46	kW	Tj = 7°C	COPd	5.72	-
Tj = 12°C	Pdh	0.82	kW	Tj = 12°C	COPd	5.77	-
Tj = bivalent temperature	Pdh	4.50	kW	Tj = bivalent temperature	COPd	2.53	-
Tj = operating limit	Pdh	3.60	kW	Tj = operating limit	COPd	2.12	-
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2°C	Pdh	-	kW	Tj = 2°C	COPd	-	-
Tj = 7°C	Pdh	-	kW	Tj = 7°C	COPd	-	-
Tj = 12°C	Pdh	-	kW	Tj = 12°C	COPd	-	-
Tj = bivalent temperature	Pdh	-	kW	Tj = bivalent temperature	COPd	-	-
Tj = operating limit	Pdh	-	kW	Tj = operating limit	COPd	-	-
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	-	kW	Tj = -7°C	COPd	-	-
Tj = 2°C	Pdh	-	kW	Tj = 2°C	COPd	-	-
Tj = 7°C	Pdh	-	kW	Tj = 7°C	COPd	-	-
Tj = 12°C	Pdh	-	kW	Tj = 12°C	COPd	-	-
Tj = bivalent temperature	Pdh	-	kW	Tj = bivalent temperature	COPd	-	-
Tj = operating limit	Pdh	-	kW	Tj = operating limit	COPd	-	-
Tj = -15°C	Pdh	-	kW	Tj = -15°C	COPd	-	-

Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling	YES			Average (mandatory)	YES		
Heating	YES			Warmer (if designated)	NO		
				Colder (if designated)	NO		
Item	symbol	value	unit	Item	symbol	value	unit
Bivalent temperature				Operating limit temperature			
heating/Average	Tbiv	-10	°C	heating/Average	Tol	-15	°C
heating/Warmer	Tbiv	-	°C	heating/Warmer	Tol	-	°C
heating/Colder	Tbiv	-	°C	heating/Colder	Tol	-	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc	-	kW	for cooling	EERcyc	-	-
for heating	Peych	-	kW	for heating	COPcyc	-	-
Degradation co-efficient cooling(**)	Cdc	0.25	-	Degradation co-efficient heating(**)	Cdh	0.25	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	P _{OFF}	10	W	cooling	Q _{CE}	250	kWh/a
standby mode	P _{SB}	10	W	heating/Average	Q _{HE}	1500	kWh/a
thermostat-off mode	P _{TO}	30	W	heating/Warmer	Q _{HE}	-	kWh/a
crankcase heater mode	P _{CK}	0	W	heating/Colder	Q _{HE}	-	kWh/a
Capacity control (indicate one of three options)				Other Items			
fixed	NO			Sound Power Level (indoor1/ indoor2/ outdoor)	LWA	58/ 58/ 65	dB(A)
staged	NO			Global warming potential	GWP	675	kgCO2 eq.
variable	YES			Cooling/Rated air flow (indoor1/ indoor2/ outdoor)	-	654/ 654/ 2094	m ³ /h
Contact details for obtaining more information	Name and address of the manufacturer or of its authorized representative. Panasonic Testing Centre, Panasonic Marketing Europe GmbH Winsbergring 15, 22525 Hamburg, Germany						
<p>(*) For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.</p> <p>(**) If default Cd = 0,25 is chosen then (results from) cycling tests</p>							

Ürün Bilgisi

Marka Panasonic
Ürün Tipi Klima
Model Adı CS-TZ25TKEW + CS-TZ25TKEW / CU-2TZ50TBE

Vişlev (mevcutsa belirtiniz)				İşlev ısıtmayı içeriyorsa, bilginin ait olduğu ısıtma sezonunu belirtiniz. Belirtilen değerler her defasında tek bir ısıtma sezonuna ait olmalıdır. En azından "ortalama" ısıtma sezonunu belirtiniz.			
Soğutma	Evet			Ortalama (zorunlu)	Evet		
Isıtma	Evet			Daha sıcak (belirlenmişse)	Hayır		
				Daha soğuk (belirlenmişse)	Hayır		
Konu	Sembol	Değer	Birim	Konu	Sembol	Değer	Birim
Tasarım yükü				Sezonsal verimlilik			
Soğutma	Pdesignc	5.00	kW	Soğutma	SEER	7.00	-
Isıtma / Ortalama	Pdesignh	4.50	kW	Isıtma / Ortalama	SCOP/A	4.20	-
Isıtma / Daha sıcak	Pdesignh	-	kW	Isıtma / Daha sıcak	SCOP/W	-	-
Isıtma / Daha soğuk	Pdesignh	-	kW	Isıtma / Daha soğuk	SCOP/C	-	-
27(19) °C iç ortam ve Tj dış ortam sıcaklığında soğutma için beyan edilen kapasite (*)				27(19) °C iç ortam ve Tj dış ortam sıcaklığında soğutma için beyan edilen enerji verimliliği katsayısı (*)			
Konu	Sembol	Değer	Birim	Konu	Sembol	Değer	Birim
Tj = 35°C	Pdc	5.00	kW	Tj = 35°C	EERd	3.85	-
Tj = 30°C	Pdc	3.50	kW	Tj = 30°C	EERd	5.40	-
Tj = 25°C	Pdc	2.25	kW	Tj = 25°C	EERd	9.17	-
Tj = 20°C	Pdc	1.47	kW	Tj = 20°C	EERd	14.36	-
20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/Ortalama sezon için beyan edilen kapasite (*)				20 °C iç ortam ve Tj dış ortam sıcaklığında Ortalama sezon için beyan edilen performans katsayısı (*)			
Tj = -7°C	Pdh	3.74	kW	Tj = -7°C	COPd	2.60	-
Tj = 2°C	Pdh	2.28	kW	Tj = 2°C	COPd	4.11	-
Tj = 7°C	Pdh	1.46	kW	Tj = 7°C	COPd	5.72	-
Tj = 12°C	Pdh	0.82	kW	Tj = 12°C	COPd	5.77	-
Tj = çift değerli sıcaklık	Pdh	4.50	kW	Tj = çift değerli sıcaklık	COPd	2.53	-
Tj = çalışma sınırı	Pdh	3.60	kW	Tj = çalışma sınırı	COPd	2.12	-
20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/ Daha sıcak sezon için beyan edilen kapasite (*)				20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/ Daha sıcak sezon için beyan edilen kapasite (*)			
Tj = 2°C	Pdh	-	kW	Tj = 2°C	COPd	-	-
Tj = 7°C	Pdh	-	kW	Tj = 7°C	COPd	-	-
Tj = 12°C	Pdh	-	kW	Tj = 12°C	COPd	-	-
Tj = çift değerli sıcaklık	Pdh	-	kW	Tj = çift değerli sıcaklık	COPd	-	-
Tj = çalışma sınırı	Pdh	-	kW	Tj = çalışma sınırı	COPd	-	-
20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/Daha soğuk sezon için beyan edilen kapasite (*)				20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/Daha soğuk sezon için beyan edilen kapasite (*)			
Tj = -7°C	Pdh	-	kW	Tj = -7°C	COPd	-	-
Tj = 2°C	Pdh	-	kW	Tj = 2°C	COPd	-	-
Tj = 7°C	Pdh	-	kW	Tj = 7°C	COPd	-	-
Tj = 12°C	Pdh	-	kW	Tj = 12°C	COPd	-	-
Tj = çift değerli sıcaklık	Pdh	-	kW	Tj = çift değerli sıcaklık	COPd	-	-
Tj = çalışma sınırı	Pdh	-	kW	Tj = çalışma sınırı	COPd	-	-
Tj = -15°C	Pdh	-	kW	Tj = -15°C	COPd	-	-

İşlev (mevcutsa belirtiniz)				İşlev ısıtmayı içeriyorsa, bilginin ait olduğu ısıtma sezonunu belirtiniz. Belirtilen değerler her defasında tek bir ısıtma sezonuna ait olmalıdır. En azından "ortalama" ısıtma sezonunu belirtiniz.			
Soğutma	Evet			Ortalama (zorunlu)	Evet		
Isıtma	Evet			Daha sıcak (belirlenmişse)	Hayır		
				Daha soğuk (belirlenmişse)	Hayır		
Konu	Sembol	Değer	Birim	Konu	Sembol	Değer	Birim
Çift değerli sıcaklık				Çalışma sınır sıcaklığı			
Isıtma/Ortalama	Tbiv	-10	°C	Isıtma/Ortalama	Tol	-15	°C
Isıtma/Daha sıcak	Tbiv	-	°C	Isıtma/Daha sıcak	Tol	-	°C
Isıtma/Daha soğuk	Tbiv	-	°C	Isıtma/Daha soğuk	Tol	-	°C
Çevrim aralığı kapasitesi				Çevrim aralığı verimliliği			
Soğutma için	Pcycc	-	kW	Soğutma için	EERcyc	-	-
Isıtma için	Pcych	-	kW	Isıtma için	COPcyc	-	-
İndirgenme katsayısı soğutma (**)	Cdc	0.25	-	İndirgenme katsayısı ısıtma (**)	Cdh	0.25	-
Çalışma modu haricinde kalan güç modları için elektrik güç girişi				Yıllık elektrik tüketimi			
Kapalı mod	P _{OFF}	10	W	soğutma	Q _{CE}	250	kWh/yıl
Hazırda bekleme modu	P _{SB}	10	W	ısıtma/Ortalama	Q _{HE}	1500	kWh/yıl
Termostatla kapalı mod	P _{TO}	30	W	ısıtma/Daha sıcak	Q _{HE}	-	kWh/yıl
Karter ısıtıcı modu	P _{CK}	0	W	ısıtma/Daha soğuk	Q _{HE}	-	kWh/yıl
Kapasite Kontrolü (üç seçenektan birini belirtiniz)				Diğer konular			
sabit	Hayır			Ses gücü seviyesi (iç Ünite 1/ iç Ünite 2 dış Ünite)	LWA	58/ 58/ 65	dB(A)
kademeli	Hayır			Küresel ısıtma potansiyeli	GWP	675	kgCO2 eşd.
değişken	Evet			Hesaplanan hava akışı	-	654/ 654/ 2094	m ³ /h
Daha fazla bilgi için irtibat detayları	İmalatçının veya yetkili temsilcisinin isim ve adresi Panasonic Testing Centre Panasonic Marketing Europe GmbH Winsbergring 15, 22525 Hamburg, Germany						
*) kademeli kapasiteye sahip birimler için ,birimin beyan edilen kapasitesi, ve ,birimin beyan edilen EER/COP değerleri, bölümlerinde her bir kutucuğa („/“) işareti ile ayrılmış iki değer yazılacaktır.							
(**) Veri Cd = 0,25 olarak seçildiğinde, çevrim testlerinin sonuçlarına ihtiyaç yoktur. Aksi taktirde, ısıtma veya soğutma çevrim testinin değeri gerekir.							