

JG79Y746H02



Technical specifications table for MSZ-FT25VGK, MSZ-FT35VGK, and MSZ-FT50VGK models, including indoor/outdoor unit info, sound power levels, refrigerant type, and SEER/SCOP efficiency ratings.

Table listing the product name in various languages including German, French, Spanish, Italian, Swedish, Polish, Slovenian, Estonian, Maltese, Russian, and others.

Table listing product names in various languages including German, French, Spanish, Italian, Swedish, Polish, Slovenian, Estonian, Maltese, Russian, and others, along with a large table of performance and safety parameters in multiple languages.

PRODUCT INFORMATION (*1)

ROOM AIR CONDITIONER	INDOOR MODEL	MSZ-FT25VG / MSZ-FT25VGK
	OUTDOOR MODEL	MUZ-FT25VGHZ

Function (indicate if present)	
cooling	Y
heating	Y

If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.	
Average (mandatory)	Y
Warmer (if designated)	Y
Colder (if designated)	Y

Item	symbol	value	unit
Design load			
cooling	Pdesignc	2.5	kW
heating/Average	Pdesignh	3.2	kW
heating/Warmer	Pdesignh	1.8	kW
heating/Colder	Pdesignh	4.7	kW

Item	symbol	value	unit
Seasonal efficiency			
cooling	SEER	8.6	-
heating/Average	SCOP/A	4.6	-
heating/Warmer	SCOP/W	5.8	-
heating/Colder	SCOP/C	3.5	-

Declared capacity for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
Tj=35°C	Pdc	2.5	kW
Tj=30°C	Pdc	1.9	kW
Tj=25°C	Pdc	1.2	kW
Tj=20°C	Pdc	1.2	kW

Declared energy efficiency ratio, at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj=35°C	EERd	4.4	-
Tj=30°C	EERd	6.7	-
Tj=25°C	EERd	10.6	-
Tj=20°C	EERd	15.0	-

Declared capacity for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	2.9	kW
Tj=2°C	Pdh	1.8	kW
Tj=7°C	Pdh	1.2	kW
Tj=12°C	Pdh	0.9	kW
Tj=bivalent temperature	Pdh	3.2	kW
Tj=operating limit	Pdh	3.0	kW

Declared coefficient of performance/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	COPd	2.8	-
Tj=2°C	COPd	4.7	-
Tj=7°C	COPd	5.8	-
Tj=12°C	COPd	7.1	-
Tj=bivalent temperature	COPd	2.5	-
Tj=operating limit	COPd	1.8	-

Declared capacity for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	Pdh	1.8	kW
Tj=7°C	Pdh	1.2	kW
Tj=12°C	Pdh	0.9	kW
Tj=bivalent temperature	Pdh	1.8	kW
Tj=operating limit	Pdh	3.0	kW

Declared coefficient of performance/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	COPd	4.7	-
Tj=7°C	COPd	5.8	-
Tj=12°C	COPd	7.1	-
Tj=bivalent temperature	COPd	4.7	-
Tj=operating limit	COPd	1.8	-

Declared capacity for heating/Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	2.9	kW
Tj=2°C	Pdh	1.8	kW
Tj=7°C	Pdh	1.2	kW
Tj=12°C	Pdh	0.9	kW
Tj=bivalent temperature	Pdh	3.2	kW
Tj=operating limit	Pdh	3.0	kW
Tj=-15°C	Pdh	3.6	kW

Declared coefficient of performance/Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	COPd	2.8	-
Tj=2°C	COPd	4.7	-
Tj=7°C	COPd	5.8	-
Tj=12°C	COPd	7.1	-
Tj=bivalent temperature	COPd	2.5	-
Tj=operating limit	COPd	1.8	-
Tj=-15°C	COPd	1.9	-

Bivalent temperature			
heating/Average	Tbiv	-10	°C
heating/Warmer	Tbiv	2	°C
heating/Colder	Tbiv	-10	°C

Operating limit temperature			
heating/Average	Tol	-25	°C
heating/Warmer	Tol	-25	°C
heating/Colder	Tol	-25	°C

Cycling interval capacity			
for cooling	Pcycc	x	kW
for heating	Pcyh	x	kW
Degradation co-efficient cooling	Cdc	0.25	-

Cycling interval efficiency			
for cooling	EERcyc	x	-
for heating	COPcyc	x	-
Degradation co-efficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'			
off mode	P _{OFF}	1	W
standby mode	P _{SB}	1	W
thermostat - off mode	P _{TO}	8	W
crankcase heater mode	P _{CK}	0	W

Annual electricity consumption			
cooling	Q _{CE}	101	kWh/a
heating/Average	Q _{HE}	973	kWh/a
heating/Warmer	Q _{HE}	432	kWh/a
heating/Colder	Q _{HE}	2766	kWh/a

Capacity control (indicate one of three options)			
fixed		N	
staged		N	
variable		Y	

Other items			
Sound power level (indoor/outdoor)	L _{WA}	60/60	dB(A)
Global warming potential	GWP (*2)	675	kgCO ₂ eq.
Rated air flow (indoor/outdoor)		738/1824	m ³ /h

Contact details for obtaining more information	MITSUBISHI ELECTRIC CORPORATION SHIZUOKA WORKS 3-18-1, Oshika, Suruga-ku, Shizuoka 422-8528, Japan E-mail: melshierp@MitsubishiElectric.co.jp
--	---

(*1) This information is based on the "product information requirement" in COMMISSION REGULATION (EU) No. 206/2012.

(*2) This GWP value is based on Regulation(EU)No. 517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No. 626/2001, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.

TECHNICAL DOCUMENTATION (1)

ROOM AIR CONDITIONER	INDOOR MODEL	MSZ-FT25VG / MSZ-FT25VGK	280H*838W*229D (mm)
	OUTDOOR MODEL	MUZ-FT25VGHZ	550H*800W*285D (mm)

Function	
cooling	Y
heating	Y


The heating season	
Average (mandatory)	Y
Warmer (if designated)	Y
Colder (if designated)	Y

Capacity control	
fixed	N
staged	N
variable	Y

Item	symbol	value	unit
Seasonal efficiency (2)			
cooling	SEER	8.6	-
heating/Average	SCOP/A	4.6	-
heating/Warmer	SCOP/W	5.8	-
heating/Colder	SCOP/C	3.5	-

Energy efficiency class			
cooling	SEER	A+++	-
heating/Average	SCOP/A	A++	-
heating/Warmer	SCOP/W	A+++	-
heating/Colder	SCOP/C	A	-

Other items			
Sound power level (indoor/outdoor)	L _{WA}	60/60	dB(A)
Refrigerant	-	R32	-
Global warming potential	GWP (3)	675	kgCO ₂ eq.

identification and signature of the person empowered to bind the supplier	
	Tadashi Saito Department Manager, Quality Assurance Department MITSUBISHI ELECTRIC CONSUMER PRODUCTS(THAILAND) CO.,LTD

(1) This information is based on COMMISSION DELEGATED REGULATION (EU)No. 626/2011.

(2) SEER/SCOP values are measured based on EN 14825:2016: Testing and rating at part load conditions and calculation of seasonal performance.

(3) This GWP value is based on Regulation(EU)No. 517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No. 626/2001, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.