

Product Ecodesign Information

Brand Panasonic
Type of product Air-conditioner
Model name CS-NZ35VKE / CU-NZ35VKE

Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling				Average (mandatory)			
Heating				Warmer (if designated)			
				Colder (if designated)			
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	3.50	kW	cooling	SEER	7.40	-
heating/Average	Pdesignh	3.60	kW	heating/Average	SCOP/A	4.70	-
heating/Warmer	Pdesignh	-	kW	heating/Warmer	SCOP/W	-	-
heating/Colder	Pdesignh	4.90	kW	heating/Colder	SCOP/C	3.80	-
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = 35°C	Pdc	3.50	kW	Tj = 35°C	EERd	3.94	-
Tj = 30°C	Pdc	2.66	kW	Tj = 30°C	EERd	6.11	-
Tj = 25°C	Pdc	1.72	kW	Tj = 25°C	EERd	9.59	-
Tj = 20°C	Pdc	1.48	kW	Tj = 20°C	EERd	13.63	-
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	3.22	kW	Tj = -7°C	COPd	3.01	-
Tj = 2°C	Pdh	1.94	kW	Tj = 2°C	COPd	4.73	-
Tj = 7°C	Pdh	1.24	kW	Tj = 7°C	COPd	5.94	-
Tj = 12°C	Pdh	1.29	kW	Tj = 12°C	COPd	7.40	-
Tj = bivalent temperature	Pdh	3.60	kW	Tj = bivalent temperature	COPd	2.63	-
Tj = operating limit	Pdh	2.66	kW	Tj = operating limit	COPd	1.80	-
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2°C	Pdh	-	kW	Tj = 2°C	COPd	-	-
Tj = 7°C	Pdh	-	kW	Tj = 7°C	COPd	-	-
Tj = 12°C	Pdh	-	kW	Tj = 12°C	COPd	-	-
Tj = bivalent temperature	Pdh	-	kW	Tj = bivalent temperature	COPd	-	-
Tj = operating limit	Pdh	-	kW	Tj = operating limit	COPd	-	-
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	3.09	kW	Tj = -7°C	COPd	3.09	-
Tj = 2°C	Pdh	1.85	kW	Tj = 2°C	COPd	4.74	-
Tj = 7°C	Pdh	1.18	kW	Tj = 7°C	COPd	6.15	-
Tj = 12°C	Pdh	1.29	kW	Tj = 12°C	COPd	7.40	-
Tj = bivalent temperature	Pdh	4.00	kW	Tj = bivalent temperature	COPd	2.20	-
Tj = operating limit	Pdh	2.66	kW	Tj = operating limit	COPd	1.80	-
Tj = -15°C	Pdh	4.00	kW	Tj = -15°C	COPd	2.20	-

Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling	YES		Average (mandatory)		YES		
Heating	YES		Warmer (if designated)		NO		
			Colder (if designated)		YES		
Item	symbol	value	unit	Item	symbol	value	unit
Bivalent temperature				Operating limit temperature			
heating/Average	Tbiv	-10	°C	heating/Average	Tol	-25	°C
heating/Warmer	Tbiv	-	°C	heating/Warmer	Tol	-	°C
heating/Colder	Tbiv	-15	°C	heating/Colder	Tol	-25	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc	-	kW	for cooling	EERcyc	-	-
for heating	Pcych	-	kW	for heating	COPcyc	-	-
Degradation co-efficient cooling(**)	Cdc	0.25	-	Degradation co-efficient heating(**)	Cdh	0.25	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	P _{OFF}	4	W	cooling	Q _{CE}	166	kWh/a
standby mode	P _{SB}	4	W	heating/Average	Q _{HE}	1072	kWh/a
thermostat-off mode	P _{TO}	31	W	heating/Warmer	Q _{HE}	-	kWh/a
crankcase heater mode	P _{CK}	0	W	heating/Colder	Q _{HE}	2708	kWh/a
Capacity control (indicate one of three options)				Other Items			
fixed	NO		Sound power level (indoor/outdoor)		LWA	58 / 63	dB(A)
staged	NO		Global warming potential		GWP	675	kgCO ₂ eq.
variable	YES		Cooling/Rated air flow (indoor/outdoor)		-	678 / 2034	m ³ /h
Contact details for obtaining more information	Name and address of the manufacturer or of its authorized representative. Panasonic Marketing Europe GmbH Hagenauer Strasse 43, 65203 Wiesbaden, Germany						

(*) For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.

(**) If default Cd = 0,25 is chosen then (results from) cycling tests

Ürün Eco-dizayn Bilgisi

Marka Panasonic
Ürün Tipi Klima
Model Adı CS-NZ35VKE / CU-NZ35VKE

İşlev (mevcutsa belirtiniz)				İşlev ısıtmayı içeriyorsa, bilginin ait olduğu ısıtma sezonunu belirtiniz. Belirtilen değerler her defasında tek bir ısıtma sezonuna ait olmalıdır. En azından "ortalama" ısıtma sezonunu belirtiniz.			
Soğutma		Evet		Ortalama (zorunlu)		Evet	
Isıtma		Evet		Daha sıcak (belirlenmişse)		Hayır	
				Daha soğuk (belirlenmişse)		Evet	
Konu	Sembol	Değer	Birim	Konu	Sembol	Değer	Birim
Tasarım yükü				Sezonal verimlilik			
Soğutma	Pdesignc	3.50	kW	Soğutma	SEER	7.40	-
Isıtma / Ortalama	Pdesignh	3.60	kW	Isıtma / Ortalama	SCOP/A	4.70	-
Isıtma / Daha sıcak	Pdesignh	-	kW	Isıtma / Daha sıcak	SCOP/W	-	-
Isıtma / Daha soğuk	Pdesignh	4.90	kW	Isıtma / Daha soğuk	SCOP/C	3.80	-
27(19) °C iç ortam ve Tj dış ortam sıcaklığında soğutma için beyan edilen kapasite (*)				27(19) °C iç ortam ve Tj dış ortam sıcaklığında soğutma için beyan edilen enerji verimliliği katsayısı (*)			
Konu	Sembol	Değer	Birim	Konu	Sembol	Değer	Birim
Tj = 35°C	Pdc	3.50	kW	Tj = 35°C	EERd	3.94	-
Tj = 30°C	Pdc	2.66	kW	Tj = 30°C	EERd	6.11	-
Tj = 25°C	Pdc	1.72	kW	Tj = 25°C	EERd	9.59	-
Tj = 20°C	Pdc	1.48	kW	Tj = 20°C	EERd	13.63	-
20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/Ortalama sezon için beyan edilen kapasite (*)				20 °C iç ortam ve Tj dış ortam sıcaklığında Ortalama sezon için beyan edilen performans katsayısı (*)			
Tj = -7°C	Pdh	3.22	kW	Tj = -7°C	COPd	3.01	-
Tj = 2°C	Pdh	1.94	kW	Tj = 2°C	COPd	4.73	-
Tj = 7°C	Pdh	1.24	kW	Tj = 7°C	COPd	5.94	-
Tj = 12°C	Pdh	1.29	kW	Tj = 12°C	COPd	7.40	-
Tj = çift değerli sıcaklık	Pdh	3.60	kW	Tj = çift değerli sıcaklık	COPd	2.63	-
Tj = çalışma sınırı	Pdh	2.66	kW	Tj = çalışma sınırı	COPd	1.80	-
20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/ Daha sıcak sezon için beyan edilen kapasite (*)				20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/ Daha sıcak sezon için beyan edilen kapasite (*)			
Tj = 2°C	Pdh	-	kW	Tj = 2°C	COPd	-	-
Tj = 7°C	Pdh	-	kW	Tj = 7°C	COPd	-	-
Tj = 12°C	Pdh	-	kW	Tj = 12°C	COPd	-	-
Tj = çift değerli sıcaklık	Pdh	-	kW	Tj = çift değerli sıcaklık	COPd	-	-
Tj = çalışma sınırı	Pdh	-	kW	Tj = çalışma sınırı	COPd	-	-
20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/Daha soğuk sezon için beyan edilen kapasite (*)				20 °C iç ortam ve Tj dış ortam sıcaklığında ısıtma/Daha soğuk sezon için beyan edilen kapasite (*)			
Tj = -7°C	Pdh	3.09	kW	Tj = -7°C	COPd	3.09	-
Tj = 2°C	Pdh	1.85	kW	Tj = 2°C	COPd	4.74	-
Tj = 7°C	Pdh	1.18	kW	Tj = 7°C	COPd	6.15	-
Tj = 12°C	Pdh	1.29	kW	Tj = 12°C	COPd	7.40	-
Tj = çift değerli sıcaklık	Pdh	4.00	kW	Tj = çift değerli sıcaklık	COPd	2.20	-
Tj = çalışma sınırı	Pdh	2.66	kW	Tj = çalışma sınırı	COPd	1.80	-
Tj = -15°C	Pdh	4.00	kW	Tj = -15°C	COPd	2.20	-

İşlev (mevcutsa belirtiniz)				İşlev ısıtmayı içeriyorsa, bilginin ait olduğu ısıtma sezonunu belirtiniz. Belirtilen değerler her defasında tek bir ısıtma sezonuna ait olmalıdır. En azından "ortalama" ısıtma sezonunu belirtiniz.												
Soğutma	Evet		Ortalama (zorunlu)		Evet											
Isıtma	Evet		Daha sıcak (belirlenmişse)		Hayır											
				Daha soğuk (belirlenmişse)	Evet											
Konu	Sembol	Değer	Birim	Konu	Sembol	Değer	Birim									
Çift değerli sıcaklık				Çalışma sınır sıcaklığı												
Isıtma/Ortalama	T _{biv}	-10	°C	Isıtma/Ortalama	T _{ol}	-25	°C									
Isıtma/Daha sıcak	T _{biv}	-	°C	Isıtma/Daha sıcak	T _{ol}	-	°C									
Isıtma/Daha soğuk	T _{biv}	-15	°C	Isıtma/Daha soğuk	T _{ol}	-25	°C									
Çevrim aralığı kapasitesi				Çevrim aralığı verimliliği												
Soğutma için	P _{cyc}	-	kW	Soğutma için	EER _{cyc}	-	-									
Isıtma için	P _{cych}	-	kW	Isıtma için	COP _{cyc}	-	-									
İndirgenme katsayısı soğutma (**)	C _{dc}	0.25	-	İndirgenme katsayısı ısıtma (**)	C _{dh}	0.25	-									
Çalışma modu haricinde kalan güç modları için elektrik güç girişi				Yıllık elektrik tüketimi												
Kapalı mod	P _{OFF}	4	W	soğutma	Q _{CE}	166	kWh/yıl									
Hazırda bekleme modu	P _{SB}	4	W	isıtma/Ortalama	Q _{HE}	1072	kWh/yıl									
Termostatla kapalı mod	P _{To}	31	W	isıtma/Daha sıcak	Q _{HE}	-	kWh/yıl									
Karter ısıtıcı modu	P _{CK}	0	W	isıtma/Daha soğuk	Q _{HE}	2708	kWh/yıl									
Kapasite Kontrolü (üç seçenekten birini belirtiniz)				Diğer konular												
sabit	Hayır		Ses gücü seviyesi (iç ortam/dış ortam)		LWA	58 / 63	dB(A)									
kademeli	Hayır		Küresel ısınma potansiyeli		GWP	675	kgCO ₂ eşd.									
değişken	Evet		Hesaplanan hava akışı		-	678 / 2034	m ³ /h									
Daha fazla bilgi için irtibat detayları	İmalatçının veya yetkili temsilcisinin isim ve adresi Panasonic Marketing Europe GmbH Hagenauer Strasse 43, 65203 Wiesbaden, Germany															
*) kademeli kapasiteye sahip birimler için ,birimin beyan edilen kapasitesi, ve ,birimin beyan edilen EER/COP değerleri, böülümlerinde her bir kutucuğa (,,/) işaret ile ayrılmış iki değer yazılacaktır.																
(**) Veri Cd = 0,25 olarak seçildiğinde, çevrim testlerinin sonuçlarına ihtiyaç yoktur. Aksi taktirde, ısıtma veya soğutma çevrim testinin değeri gerekir.																